

## **TAMIL NADU FIRE - RESCUE SERVICES**

### **FIRE SERVICE LICENSE**

(Under Section 13 of the Tamil Nadu Fire Service Act 1985  
and with Tamil Nadu Service Rules 1990-Appendix-III)

**S.L.No:-16/2024.**

**L.Dis No:-285/B/2024.**

**Date:- 11.01.2024.**


License is hereby granted under Section 13 of the Tamil Nadu Fire Service Act 1985, for Running a College within the jurisdiction of Perambalur Taluk, S.F.No:- 80/4B, 5, 7, 8, 9, 10, 11 at the premises **M/s.Dhanalakshmi Srinivasan Charitable & Educational Trust, Dhanalakshmi Srinivasan Arts & Science College For Women ("A" Block), Aranarai South Village, Thuraiyur road, Perambalur District. 621212.** Subject to the conditions noted thereon and other conditions as may be prescribed.

The above Premises Inspected By District Officer, Perambalur on:-11.01.2024

### **CONDITIONS**

As per Col.13 of Appendix V to the Rules under section 13 of the Act

1. Installation of fire and safety system should be maintained as per National Building code of India -2016 – part IV Fire Safety code of practice.
2. The applicant will also get permission / No objection certificate from other department if necessary.
3. This License is valid for one year from the date of issue.
4. If the extension or alteration is made in the existing building and also for Changing of present business will also apply & get separate permission.
5. Regular License has to be obtained from competent authority.
6. All the Fire extinguishers have to be recharged and maintained Periodically as per code of practice in IS: 2190/2010.
7. Advise to train the employee to operate the fire extinguisher.
8. If there is any deviation from the Govt. rules and act the license stand cancelled.
9. Hose reel system should be provided.
10. A Terrace tank with capacity of 10000 litres should be provided.
11. In compliance to section 3.2 of BIS 12459:1988 – Code of practice for fire safety in cable regularization, a transparent fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.



*V. Jey*  
11/1/2024  
**District Officer**  
**Fire and Rescue Service,**  
**Perambalur District,**  
**Perambalur.**

**To:-** M/s.Dhanalakshmi Srinivasan Charitable & Educational Trust,  
Dhanalakshmi Srinivasan Arts & Science College For Women ("A" Block),  
Aranarai South Village, Thuraiyur road,  
Perambalur Taluk & District - 621212.

Copy to: Deputy Director, Fire and Rescue Service, Central Region, Tiruchirappalli.

*m. a.*  
**DIRECTOR**  
**Dhanalakshmi Srinivasan**  
**College of Arts & Science for Women,**  
**PERAMBALUR - 621 218.**

